

TOWN OF EASTON - BUILDING DEPARTMENT

E.W. "Bill" Martin
Building Official
225 Center Road
Easton, CT.06612

Telephone 203-268-6291
Fax 203-268-4928

ADDRESS _____

2005 CONNECTICUT STATE BUILDING CODE
IRC R-313 AND CONNECTICUT STATE STATUES

SMOKE DETECTOR AND CARBON MONOXIDE DETECTORS SHALL BE
INSTALLED IN THE FOLLOWING LOCATIONS

SMOKE DETECTORS

1. In each sleeping room.
2. Outside each sleeping area in the immediate vicinity of.
3. In each story within the dwelling unit, including basements.

CARBON MONOXIDE DETECTORS

1. Outside each sleeping area in the immediate vicinity of.
2. In each story within the dwelling unit.

When alterations or additions requiring a building permit occur or when one or more sleeping rooms are added or created in existing buildings, the entire building shall be provided with smoke detectors and carbon monoxide detectors located as required for new dwelling units.

I AGREE TO COMPLY WITH ABOVE CODE REQUIREMENTS

Signature of Homeowner or Holder of Permit:

HOMEOWNER: _____

PERMIT HOLDER: _____

PERMIT NUMBER: _____